



ADDENDUM No. 2
Request for Competitive Sealed Proposals (CSP)
19CSP051 Roof Improvements at Walnut Creek Elementary
School

November 26, 2018

Item 1: Revisions to Division 7 Item 2.1.B. Clarifications attached

Item 2: Revisions to Drawing Sheet A102- Scope of Work Alternate Bids. Clarifications attached

Item 3: Revisions to Drawing Sheet A201- Keyed Roof Plan Notes. Clarifications attached



Date: November 16, 2018

To: All Plan Holders

RE: Walnut Creek Elementary School
 Austin Independent School District
 AISD Project No. 18-0028-WALCK
 EE Project No. 004-012



ADDENDUM NO. 2

This addendum applies to the Bidding Documents for the subject project, prepared by Engineered Exteriors, PLLC, dated September 18, 2018, and shall be included as part of the Contract Documents.

PROJECT MANUAL

Div	Section	Item	Revision
07	072200	2.1.B	<p><i>After paragraph 2.1.B: Add the following</i></p> <p>“C. Ladder:</p> <p>1. Roof Hatch Ladder:</p> <p>a. O’Keefe’s, Inc. Model 500, standard duty channel rail aluminum wall ladder.</p> <p>b. Finish: Anodized Aluminum.”</p>

DRAWINGS

Sheet	Revision
A102	Scope of Work - Alternate Bids , Note 2.a: Change “Remove existing damaged skylights indicated in the Drawings.” to read “Remove and replace all skylights on Roof Area A-11 (Total of 8 skylights).”
A201	Keyed Roof Plan Notes , Note 4: Change “Install new roof hatch and safety rail” to read “Install new roof hatch, safety rail, and ladder”

END OF ADDENDUM NO. 2