

ADDENDUM No. 2
Request for Competitive Sealed Proposals (CSP)
20CSP043 Upgrades at Winn Elementary School

October 21, 2019

Received by bidder:

Date: _____

Name: _____

Signature: _____

Item 1: Questions and Answers

Question: On the roofing plans R-100 it has a detail for roof guardrail that is penetrating the roof system at the edge metal. Then in the specifications (077200) it is asking for a non penetrating guardrail system. Leading Edge provides both types of guardrailing. Which railing system should i use to bid this project?

Answer: Please see the attached answer from AISD's consultant.

Item 2 : Clarification

Please see the attached clarification from AISD's consultant.

ADDENDUM NO. 02

PROJECT	Austin ISD – Winn Elementary School – Civil, Structural & MEP Upgrades (AISD # 19-0033) 3500 Susquehanna Lane Austin, Texas 78723
PROJECT NO.	19002
DATE	October 21, 2019

TO: All Prime Contract Bidders and all others to whom Drawings and Specifications have been issued by the Architect/Engineer.

This Addendum forms a part of the Contract Documents. This addendum modifies and supplements the Contract Documents as follows for the above-mentioned project and includes One (1) page. All other provisions of the Documents remain the same.

CLARIFICATIONS

ITEM NO. 1. BID QUESTION:

- A. The non-penetrating guardrail system is specified and shown in the drawings details. It is shown installed under the edge metal as referenced in Detail (1/R100), not penetrating through the roof. Penetrating through the roof will not be allowed.
-

CHANGES TO THE SPECIFICATIONS

ITEM NO. 2. Austin ISD – Project Development Manual – for Modern Learning Environments:

- A. The Project Development Manual provided in the specifications is only for general reference and not specific to the Winn Elementary School Project.
-

- o o o -

W:\19002_AISD Winn E.S\15-0_Bidding\Addenda\Addendum No. 1.docx

