

ADDENDUM No. 1
Request for Competitive Sealed Proposals (CSP)
21CSP016 Renovations at Joslin Elementary School

September 1st, 2020

Received by bidder:

Date: _____

Name: _____

Signature: _____

Item 1: Questions and Answers

Item 2: Modifications to Contract Documents

Item 1:

Q: When is this project supposed to start?

A: See paragraph 1.13.A of Summary Specifications 01 10 00 for anticipated project schedule. As discussed at pre-proposal meeting, AISD will consider allowing some work occurring during the school year as long as school operations are not disrupted.

Q: Does RTU cor4 need a separate electrical disconnect ?

A: Yes all new RTUs as well as ODU-CUST and ODU-MDF require a separate disconnect with rack per 4/R3.0. Provide all roofing scope noted typical for ODU-CUST at ODU-MDF as well (ref M5.1)

Q: Are walk pads needed around ODU-Cust unit on roof?

A: ODU-CUST gravel roof type does not require walk pads.

Item 2:

Modifications to Contract Documents are detailed on the following page.



SMITH HOLT
ARCHITECTURE & PROJECT MANAGEMENT

ARCH. ADDENDUM #1

September 1, 2020

To all Bidders

Owner: Austin Independent School District
Project #: 20-0016-JOSLN / 19012 (ARCH)
Name: Renovations at Joslin Elementary

This addendum modifies the Contract Documents, dated 31 July 2020, previously issued by the Architect and form part of the Scope of Work.

1.1 In Room 101 replace existing glazing at upper windows shown on 3/A-2. Provide new glazing per specification section 08 8000. New glazing shall be clear single paned glazing to match existing in color.

Acknowledgement of this Addendum and the Alternate listed is required per the Project Manual by inserting its number and date in the appropriate location on the Bid Form.

Cc: file



1 Sep 2020