

ADDENDUM No. 1
Request for Competitive Sealed Proposals (CSP)
21CSP068 Districtwide Kitchen Hood Suppression System District
Wide

January 29th, 2021

Received by bidder:

Date: _____

Name: _____

Signature: _____

Item 1: Questions and Answers

Q: Do you have any plans for this project?

A: Kitchen plans will not be provided. Clean CAD floor plans will be provided to the awarded Contractor for the awarded project sites.

Q: Is Ansul the only manufacturer for this system or is there some other compatible system that can be used?

A: AISD Response: Yes, Ansul is the required manufacturer for this scope of work.